

2025 Consumer Confidence Report for Public Water System EDOM WSC

PWS TX ID: 2340009 Edom WSC

**Annual Water Quality Report for the
period of January 1 to December 31, 2025**

We are pleased to present to you the Annual Water Quality Report (Consumer Confidence Report) for the year, for the period of January 1 to December 31, 2025. This report is intended to provide you with important information about your drinking water and the efforts made by the water system to provide safe drinking water.

Edom WSC board of directors meets every second Monday of the month. Regular Board meetings are held at Edom WSC Water Office beginning at 5:00 p.m. Feel free to contact the office at (903) 852-5055 or edomwater@embarqmail.com for further information.

**EDOM WSC provides Ground Water
from the Carrizo-Wilcox Aquifer located in Van Zandt County.**

For more information regarding this report contact:

Name: **John Pipes - Edom WSC Water Operator**
Phone: **(903) 852-5055**

Este reporte incluye información importante sobre el agua para tomar. Para asistencia en español, favor de llamar al telefono (903) 852-5055.

Information about your Drinking Water

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791.

Contaminants that may be present in source water include:

- Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
- Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
- Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

Some people may be more vulnerable to contaminants in drinking water than the general population. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.

Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

Lead can cause serious health effects in people of all ages, especially pregnant people, infants (both formula-fed and breastfed), and young children. Lead in drinking water is primarily from materials and parts used in service lines and in home plumbing. **EDOM WSC is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in the plumbing in your home.** Because lead levels may vary over time, lead exposure is possible even when your tap sampling results do not detect lead at one point in time. You can help protect yourself and your family by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Using a filter, certified by an American National Standards Institute accredited certifier to reduce lead, is effective in reducing lead exposures. Follow the instructions provided with the filter to ensure the filter is used properly. Use only cold water for drinking, cooking, and making baby formula. Boiling water does not remove lead from water. Before using tap water for drinking, cooking, or making baby formula, flush your pipes for several minutes. You can do this by running your tap, taking a shower, doing laundry or a load of dishes. If you have a lead service line or galvanized requiring replacement service line, you may need to flush your pipes for a longer period. If you are concerned about lead in your water and wish to have your water tested, contact EDOM WSC at 903-852-5055. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <https://www.epa.gov/safewater/lead>.

Edom WSC has developed a service line inventory of Edom WSC service lines and customer owned service lines. This inventory provides critical information for our water system to address significant sources of lead in drinking water. To access the inventory, please contact our office at (903)852-5055.

Cross-Connection Control and Backflow Prevention

Your Role as a Water Customer

By taking steps to control cross connections and prevent the possibility of backflow at your home, you will help to protect the public water supply and ensure that your family continues to enjoy safe drinking water. Garden hoses and irrigation systems are common concerns, but there are other common residential sources of cross connections, too.

Garden Hoses and Backflow

The garden hose is the most common cross connection. Each of these common uses of a garden hose sets up a cross connection:

- forcing it into a clogged gutter, downspout, or sewer pipe to flush out the clog
- connecting it directly to a hose-end sprayer to apply pesticide or fertilizer to your yard
- connecting it to a soap-and-brush attachment to wash your car, boat, or siding
- letting the end of the hose lie in a puddle or pool of water on the ground

No doubt you can think of other examples. In each of these cases, if backflow happens, your household's water lines could be contaminated.

Depending on how long the backflow event lasts, the contamination could spread to the public drinking water system. Fortunately, there are two inexpensive ways to solve this problem:

- Make sure that the end of your garden hose is **never submerged in or connected to a non-potable substance**. This solution is free, but not highly reliable. Can you always be this careful?
- Install a **hose bib vacuum breaker** on each of your outside faucets. These inexpensive devices are designed to allow water to flow in only one direction. You can find them at most home supply stores and through plumbing suppliers. Before you use a hose-end sprayer, you should first install a hose bib vacuum breaker at the faucet.

Irrigation Systems and Backflow

As a homeowner, you may install and maintain your own irrigation system, but it's still important to have a suitable backflow prevention assembly (BPA) in place and to be sure that it works properly. Here are a few ways you can do just that:

- Hire a licensed irrigator. You can find one from our online licensing database – http://www2.tceq.texas.gov/lic_dpa/index.cfm
- If you install your own system, have a licensed BPA tester confirm that the BPA is installed and operating properly. Licensed BPA testers are also listed in our online licensing database - http://www2.tceq.texas.gov/lic_dpa/index.cfm
- TCEQ requires you to have a licensed BPA tester check the BPA when it is installed on your irrigation system. Your water provider may have adopted additional codes or regulations which require **an annual test** of the BPA on your irrigation system. Contact Edom WSC for more information on our policies.

For more information see TCEQ's regulations for irrigation systems at <https://www.tceq.texas.gov/drinkingwater/irrigation/landscape.html>, or contact TCEQ's Landscape Irrigation Program at 512-239-LAWN.

***Information on Cross-Connection Control and Backflow Prevention obtained from TCEQ's website - <https://www.tceq.texas.gov/drinkingwater/cross-connection#public>**

2025 Consumer Confidence Report - EDOM WSC Public Water Supply ID: TX2340009

Information about Source Water

TCEQ completed an assessment of your source water, and results indicate that some of our sources are susceptible to certain contaminants. The sampling requirements for your water system is based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confidence Report. For more information on source water assessments and protection efforts at our system contact **John Pipes, Edom WSC operator at (903)852-5055 or edomwater@embarqmail.com**. For more information from TCEQ visit: <https://gisweb.tceq.texas.gov/swat/2340009>

Source Water Name	Location	Type of Water	Report Status	Location
3 - 164 CR 4801 (South Plant – Well #4)	164 CR 4801	Ground Water	<u>Active</u>	Carrizo-Wilcox Aquifer Van Zandt County
4 - FM 314 (Well #5)	10735 FM 314	Ground Water	<u>Active</u>	Carrizo-Wilcox Aquifer Van Zandt County
5 - 160 PR 8279 (Well #3)	154 VZ CR 4800	Ground Water	<u>Active</u>	Carrizo-Wilcox Aquifer Van Zandt County
6 - 299 CR 4801 (Well #6)	299 CR 4801	Ground Water	<u>Active</u>	Carrizo-Wilcox Aquifer Van Zandt County

Disinfectant Residual

Disinfectant Residual	Year	Average Level	Range of Levels Detected	MRDL	MRDLG	Unit of Measure	Violation (Y/N)	Source in Drinking Water
Chlorine (Free)	2025	1.16	.64 - 1.53	4	4	ppm	N	Water additive used to control microbes.

Lead and Copper

Definitions: Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
 Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Period	90TH Percentile: 90% of your water utility levels were less than	Range of Sampled Results (low - high)	Unit	AL	Sites Over AL	Typical Source
COPPER, FREE	2021 - 2023	0.329	0 - 0.371	ppm	1.3	0	Corrosion of household plumbing systems; Erosion of natural deposits; Leaching from wood preservatives
LEAD	2021 - 2023	0	0	ppb	15	0	Corrosion of household plumbing systems; Erosion of natural deposits

Definitions and Abbreviations

In the tables below, you will find many terms and abbreviations you might not be familiar with. To help you better understand these terms, we've provided the following definitions:

Definitions and Abbreviations	The following tables contain scientific terms and measures, some of which may require explanation.
Action Level (AL):	The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Action Level Goal (ALG):	The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.
Level 1 Assessment:	A Level 1 assessment is a study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
Level 2 Assessment:	A Level 2 assessment is a very detailed study of the water system to identify potential problems and determine (if possible) why an E. coli MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
Treatment Technique or TT:	A required process intended to reduce the level of a contaminant in drinking water.
Variances and Exemptions:	State or EPA permission not to meet an MCL or a treatment technique under certain conditions
AVG:	Average - Regulatory compliance with some MCLs are based on running annual average of monthly samples.
RAA:	Running Annual Average.
LRAA:	Locational Running Annual Average.
mrem:	millirems per year (a measure of radiation absorbed by the body)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
picocuries per liter (pCi/L):	picocuries per liter is a measure of the radioactivity in water.
na:	not applicable.

2025 Water Quality Test Results

Regulated Contaminants

In the tables below, we have shown the regulated contaminants that were detected. Chemical Sampling of our drinking water may not be required on an annual basis; therefore, information provided in this table refers back to the latest year of chemical sampling results.

Disinfection Byproducts	Sample Point	Period	Highest LRAA	Range	Unit	MCL	MCLG	Typical Source
TOTAL HALOACETIC ACIDS (HAA5)	SAMPLE SITE 5, 981 VZCR 4810, BEN WHEELER, TX	2024	3	2.8	ppb	60	0	By-product of drinking water disinfection
TTHM	12963 CR 3300, BROWNSBORO, TX	2025	13	13.1	ppb	80	0	By-product of drinking water chlorination

*The value in the Highest Level or Average Detected column is the highest average of all HAA5 sample results collected at a location over a year

*The value in the Highest Level or Average Detected column is the highest average of all TTHM sample results collected at a location over a year

Regulated Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
BARIUM	2/25/2025	0.057	0.034 - 0.057	ppm	2	2	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
DIBROMOCHLOROMETHANE	9/16/2025	4.62	1.21 - 4.62	UG/L	n/a	0.06	
FLUORIDE	2/15/2024	0.124	0.117 - 0.124	ppm	4	4	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
NITRATE	2/25/2025	0.156	0.0256 - 0.156	ppm	10	10	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits

Radiological Contaminants	Collection Date	Highest Value	Range	Unit	MCL	MCLG	Typical Source
COMBINED RADIUM (-226 & -228)	12/5/2024	1.5	1.5	pCi/L	5	0	Erosion of natural deposits

There are no additional required health effects notices.

There are no additional required health effects violation notices.